



OIL SEPARATOR DETAILS
REFER TO NOTES FOR MORE INFORMATION

APPLICABLE MODELS	FLOW RATE
TS1000 PE	1000 L/hr
TS1500 PE	1500 L/hr
TS2000 PE	2000 L/hr
TS2500 PE	2500 L/hr

NOTES:

- THIS IS A SCHEMATIC REPRESENTATION ONLY. SITE SPECIFIC INSTALLATION MAY DIFFER
- LOCAL PLUMBING REGULATIONS SHOULD BE CHECKED PRIOR TO INSTALLATION
- PRESSURE PIPE DIAMETER MUST BE CHECKED AGAINST PUMP MANUAL FOR CORRECT PIPE DIAMETER TO ENSURE PUMP WARRANTY IS NOT VOID
- PIPE MATERIAL SHOULD BE IN ACCORDANCE WITH LOCAL PLUMBING REGULATION
- COLLECTION PIT MINIMUM CAPACITY MAY APPLY DEPENDING ON INSTALLATION LOCATION

- WASH LINE TO HAVE AN APPROVED RPZ DEVICE INSTALLED IN ACCORDANCE WITH LOCAL PLUMBING REGULATIONS
- QUICK BREAK DETERGENTS MUST BE USED AT ALL TIMES. USE OF SOLVENT BASED DETERGENTS MAY EFFECT EFFICIENCY OF THE UNIT
- ALL ELECTRICAL CONNECTIONS ARE TO COMPLY WITH LOCAL REGULATIONS
- ALL GRAVITY CONNECTIONS TO BE 1:60 OR TO SUIT LOCAL PLUMBING REGULATIONS

CleanaWater®

4 Channel Rd
Mayfield West
NSW 2304

P: 1800 353 788
Email: info@cleanawater.com.au

TITLE:

ROOFED WASHBAY LAYOUT
DUAL PIT GRAVITY DISCHARGE
(POLYETHYLENE SEPARATOR)

DESIGN: RD	DATE: 17-08-2015
DRAWN: DN	SCALE: NA @ A4
CHECKED: RD	SHEET 1 OF 1
PROJECT NO:	DRAWING NO: AA902-112PE
	REVISION: A

