



SUITABLE FOR DIESEL APPLICATION ONLY

OIL SEPARATOR DETAILS
REFER TO NOTES FOR MORE INFORMATION

APPLICABLE MODELS	FLOW RATE
TS1000 SS	1000 L/hr
TS1500 SS	1500 L/hr
TS2000 SS	2000 L/hr
TS2500 SS	2500 L/hr

APPLICABLE MODELS	FLOW RATE
TS3000 SS	3000 L/hr
TS4000 SS	4000 L/hr

NOTES:

- THIS IS A SCHEMATIC REPRESENTATION ONLY, SITE SPECIFIC INSTALLATION MAY DIFFER
- LOCAL PLUMBING REGULATIONS SHOULD BE CHECKED PRIOR TO INSTALLATION
- PRESSURE PIPE DIAMETER MUST BE CHECKED AGAINST PUMP MANUAL FOR CORRECT PIPE DIAMETER TO ENSURE PUMP WARRANTY IS NOT VOID
- PIPE MATERIAL SHOULD BE IN ACCORDANCE WITH LOCAL PLUMBING REGULATION
- COLLECTION PIT MINIMUM CAPACITY MAY APPLY DEPENDING ON INSTALLATION LOCATION

- ALL ELECTRICAL CONNECTIONS ARE TO COMPLY WITH LOCAL REGULATIONS
- ALL GRAVITY CONNECTIONS TO BE 1:80 OR TO SUIT LOCAL PLUMBING REGULATIONS

CleanaWater®

4 Channel Rd
Mayfield West
NSW 2304

P: 1800 353 788
Email: info@cleanawater.com.au

TITLE:
ROOFED REFUELING AREA
DUAL PIT GRAVITY DISCHARGE
(STAINLESS STEEL SEPARATOR)

DESIGN: RD	DATE: 28-09-2015
DRAWN: DN	SCALE: NA @ A4
CHECKED: RD	SHEET 1 OF 1
PROJECT NO:	DRAWING NO: AA902-112-R
	REVISION: A

